

Important Information

The LCN SEH Sentronic is a door holder that must be installed in conjunction with a UL listed opposite-side mounted door closer or floor closer, which provides a minimum of 5 lb closing force measured 30" out on door from the hinge/pivot center line at the hold-open door position.

The hold-open feature is adjustable in 3° increments from 80° to 100°. Floor or wall stops should be used.

This instruction sheet and template apply to doors hung on butt hinges. Consult the factory if pivots or swing-clear hinges are to be used.

Installation Instructions

- The voltage shown on the track cover plate must match the voltage supplied to the door frame (24V or 120V). If concealed wiring is desired, prepare the frame to the specifications per the template on page 3. If surface wiring, mount the track to the frame before running the EMT/conduit. For 24V wiring, see the enclosed Conduit Quick Connect instruction sheet.
- 2. Remove the end cap from the track. Insert the track slide and track roller, making sure that the stud is inserted into the hole in the track slide. Reinsert the end cap into the track. Insert the track plugs into the track. Using the fasteners provided, mount the track on the frame to the dimensions of the template on page 3.
- 3. Remove the cover plate and make all the necessary electrical connections. Replace the cover plate, making sure the Test/Release button is through the hole.
- 4. Using the fastener provided, mount the rod & shoe part of the arm assembly to the door per the template on page 3.
- 5. Loosen the set screw in the end of the tube part of the arm assembly and connect to the track roller. Tighten the set screw firmly. With the track roller at the latch edge of the track, open the door part-way and insert the rod into the arm tube.
- 6. Slide the roller to the hinge edge of the track, into the hold-open position. Open the door to the desired degree of the hold-open and insert the arm adjusting screw, tightening firmly.
- 7. Turn the power on and perform the electrical checkout as follows:
 - a. With power on, open the door completely. The door should remain in the open position. If the door does not stay open, check the electrical input.
 - b. Push the release test switch. The door should close immediately. Open the door to the hold-open position and let it remain there.
 - c. The system should be checked at frequent intervals. It is suggested that step 'b' be repeated every 90 days.





